



Fire Pumps - Control Panels - Laser
 Alignment - Engine Maintenance Specialists
 Pump Calibration Digital Flow Metering -
 Consultancy & Arbitration

Head Office
 (& Midland Region) Tel: 01922 454585
 Fax: 01922 454586

Northern Region Tel: 01925 629995
Southern Region Tel: 01635 550685

JOCKEY & ELECTRICAL PUMP SERVICE CHECKLIST

Customer _____ Site _____
 Pumps _____ Type _____ Jockey _____
 Rating _____ Pressure _____ Rpm _____
 Engineer _____

IMPORTANT:- ISOLATE FROM MAINS SUPPLY BEFORE WORKING ON PLANT				
CONTROL PANEL / MOTOR				
	ELECTRIC	JOCKEY	ELECTRIC	JOCKEY
Check Panel Exterior for Damage				
Check Warning Lamps for Operation				
Check Operation of Gauges & Instruments				
Check Earthing Arrangements				
Check & Lubricate Motor / Pump Bearings				
Check & Adjust Gland Packings (if applicable)				
Check Alignment of Pump to Driver				
Check Security of Coupling				
Check for Wear, Damage & Leakage				
Check Operation of Pressure Switches				
Load Test Pump Set, Minimum Run Time 5 mins., Record all Electrical Loadings				
Inspect all Electrical Controls, Circuit Breakers, Motor Starters, Fuses, Etc.				
Check Pump Starting Sequence				
Record Pump Set Duties				
Restore Pump Set to Fully Operational Condition				

Customer's Signature.....

Date.....